







Service Factors - SF

Load Characteristics	Electric Motor, Steam Turbine Gas Turbine	Steam Engine, Water Turbine, 8 Cyl. Recip. Engine	6 Cyl. Recip. Engine	4 Cyl. Recip. Engine
 Constant Torque eg. Centrifugal pumps, compressors & blowers, light duty agitators and fans.	1.0	1.5	2.0	2.5
 Slight Fluctuations eg. Slurry pumps, Screw compressors, Lobe and Vane Blowers.	1.5	2.0	2.5	3.0
 Moderate Fluctuations and/or Slight Shock Loads Double acting pumps, Recip. Comp.	2.0	2.5	3.0	3.5
 Large Fluctuations and/or Moderate Shock Loads 1 or 2 Cylinder Recip.pumps.	2.5	3.0	3.5	4.0
 Shock Loads or Light Torque Reversals Slitters, Rod Mill, Hot Mill	3.0	3.5	4.0	Consult Factory
 Heavy Shock Loads or Large Torque Reversals Feed Rolls, Reversing Mills	Consult Factory	Consult Factory	Consult Factory	Consult Factory

- (1) Use a minimum Service Factor of 1.25 when driving through a gearbox or using a direct on-line electric motor.
- (2) Consult Autogard when using a reciprocating engine with fewer than 4 cylinders.
- (3) Service Factors provided are for reference only. Customer experience may dictate the selection of different service factors.